



HO-CHUNK NATION

DEPARTMENT OF THE TREASURY

PROCUREMENT DIVISION

February 11, 2019

ADDENDUM #1

ITB # HCGWDTREPSCT

Additions and Clarifications to Proposal

A. GENERAL NOTES

1. Prepared shop drawings showing room layout of electrical rooms with all new power and metering equipment. Equipment placement shall comply clearances to meet NEC requirements.

B. POWER METERS:

DPMH: Digital power meter with Harmonics

Mfg: Electro Industries

Part #: ENCSHK250-277-60-10-V2-D2-100S-X (Self enclosed)

Part #: SHK250-60-10-V2-D2-100S-X (SWITCHBOARD AND/OR PANEL MOUNTED). POWER SUPPLY SHALL BE PROVIDED INTERNALLY FROM THE SWITCHBOARD/PANELBOARD.

DPM: Digital power metering

Mfg: Electro Industries

Part #: ENCMP200-Y-60-10-V2-WIFI-MDSN-X

Metering notes:

1. Coordinate metering requirements on MSB-1 and DP-1 with the switchboard/panelboard manufacturer and provide same meter metering on the switchboard/panelboard inlieue of self-enclosed meter unit.
2. Provide split core C/Ts for each metering monitoring locations as recommended by the manufacturer.
3. Coordinate with the owner to provide IP address for network connection and provide Network based metering software to monitor all power meters.
4. Provide a day of field service and training from the factory trained representative.

C. TEMPORARY POWER:

1. Coordinate with the owner for power down time requirements and make provision to provide as required by the engineering division of the facility.

D. CEILING SYSTEM / FLOORING

1. Electrical Contractor to provide a 1 hour rated ceiling. Coordinate height with owner prior to issuing shop drawings. Provide four (4) 24"x24" keyed and hinged access doors painted to match ceiling. Ceiling color to be selected by the owner. The existing flooring and glue to be removed and then polished and finished to a slip resistant finish.

E. EXHAUST FAN

1. Electrical Contractor to provide a ceiling exhaust fan equal to a Greenheck model SP-A410, 300 CFM, 1000 RPM, 1.74 Amps, 3.5 Sones, 115V. The fan accessories to include a aluminum white enamel finish grille, hanging vibration isolator kit and a wall louvered discharge – Model WL – 18x6, anodized aluminum grille with damper. The exhaust fan shall run continuously thru a wall mounted time switch (adjustable). The exhaust fan shall be located in the new rated drywall ceiling near an access door.

End of Addendum

All other terms and conditions remain the same.

Catherine Link, CPPB, CAM
Procurement Manager
Ho-Chunk Nation Treasury Department
Procurement Division
W9814 Airport Road
Black River Falls, WI 54615
800-779-2873 Ext. 1502