



HO-CHUNK NATION
DEPARTMENT OF THE TREASURY
PROCUREMENT DIVISION

February 15, 2019

ADDENDUM #2

ITB # HCGWDTREPSCT

Additions and Clarifications to Proposal

Addendum Items:

Per NFPA 13 8.15.11, sprinkler protection shall be required in all electrical equipment rooms unless all of the following are met:

- (1) The room is dedicated to electrical equipment only.
- (2) Only dry-type electrical equipment is used.
- (3) Equipment is installed in a 2 hour fire-rated enclosure including protection of all penetrations
- (4) No combustible storage is permitted to be stored in the room

Extend existing fire protection wet system and install sprinkler heads to provide proper coverage in electrical equipment room. Follow all requirements in NFPA 13 pertaining to, but not limited to, clearance from obstructions and maximum sprinkler head square footage for ordinary hazard occupancy. Follow all required clearances for electrical equipment.

Project Engineer:

- Thunderbird Engineering will be the project engineer.
 - o Please direct all questions to Shawn Woldt - 608-820-1201 or email – shawnw@thunderbirdeng.com or Brian Witokoski – 414-352-2211 or email brianw@thunderbirdeng.com

End of Addendum

All other terms and conditions remain the same.

Catherine Link, CPPB, CAM
Procurement Manager
Ho-Chunk Nation Treasury Department
Procurement Division
W9814 Airport Road
Black River Falls, WI 54615
800-779-2873 Ext. 1502