



HO-CHUNK NATION
DEPARTMENT OF THE TREASURY
PROCUREMENT DIVISION

November 20, 2018

ADDENDUM #1

**ITB # HCN11052018HDSTRT Restaurant Equipment for
Wittenberg, WI Head Start**

Additions and Clarifications to Proposal

Questions and Answers

1. Define installation regarding plumbing and mechanical issues with the 2 pieces on this bid?

Answer: Complete installation and setup, we would like equipment ready for use upon completion.

2. Also what are you looking for as far as installation? Complete hook up with gas connector or delivered, set in place ready for final connections by others?

Answer: Complete installation and setup, we would like equipment ready for use upon completion.

3. Please confirm the correct building utilities will be provided to ensure proper installation?

Answer: If something needs to be changed, site contact will handle it to allow installation.

Notes:

The existing dish machine is fed via a hot water line, however the spec'd dish machine will require a cold water line and it is highly recommended that cold water line be softened prior to the dish machine.

The range specified cannot be quoted with the accessories listed. You will have to go with the GFE36-6R because the spec calls for an electronic ignitor on the burners.

Catherine Link, CPPB, CAM
Procurement Manager
Ho-Chunk Nation Treasury Department
Procurement Division
W9814 Airport Road
Black River Falls, WI 54615
800-779-2873 Ext. 1502